



## ARGB – KVBG

The ARGB-KVBG laboratory certifies the conformity with Belgian requirements for the PLT tubing kit.  
*Le laboratoire de l'ARGB certifie que le kit de tuyaux PLT est conforme aux exigences Belges.*  
Het laboratorium van de KVBG verklaart dat het PLT buisysteem conform is aan de Belgische eisen.

Certificate Number : **C-15-3695-A**  
*N° du certificat :*  
Certificaat nummer :

Date of issue : **25/02/2015**  
*Date d'édition :*  
Datum van aflevering :

Manufacturer : **Ward Manufacturing**  
*Fabricant :*  
Fabrikant : **117 Gulick Street  
USA Blossburg PA 16912-0009**

Distributor : **Soper NV**  
*Distributeur :*  
Verdelers : **Wingepark 9  
B-3110 Rotselaar**

Scope : **■ Low pressure gas installations according to the standard NBN D51-003 with  
MOP ≤ 100 mbar and diameter ≤ DN50**  
*Domaine d'application :*  
Toepassingsgebied : **■ Installations à gaz basse pression suivant la norme NBN D51-003 avec  
MOP ≤ 100 mbar and diameter ≤ DN50**  
**■ Lage druk gasinstallaties volgens de norm NBN D 51-003 met MOP ≤ 100 mbar  
en diameter ≤ DN50**

Requirements : **NBN EN 15266 'Stainless steel pliable corrugated tubing kits in buildings for gas  
with an operating pressure up to 0,5 bar'**  
*Exigences :*  
Eisen :

DVGW – certificate:	DG-4602CL0446	(8/07/2014)
DBI – report:	B13/09/1659	(17/09/2013)
DBI – report:	B13/08/1649	(21/08/2013)
MPA – report:	2012-B-4360/01/02/03	(3/12/2012)
ARGB – report:	12-3585-A	(21/08/2012)
EBI – report:	12/1134/4602/998	(30/07/2012)
EBI – report:	10/039/4602/998	(3/12/2010)
BSI – report:	239/7236717	(17/10/2008)
ARGB – report:	08-3402-A	(1/09/2008)
ARGB – report:	09-3403-B	(1/09/2008)
Lucerne University – report:	HP-07643	(11/04/2008)
MPA – report:	3675/9904	(4/07/2006)

Type:

## **Boagaz**

Stainless steel pliable corrugated tubing kits for gas

*Kits de tuyaux onduleux pliables en acier inoxydable pour le gaz*

Roestvast stalen buigzame gegolfde buissystemen voor gas

**MOP:** 0,5 bar / **GT:** 0,1 bar

**DN:** 15 – 20 – 25 – 32 – 40 – 50

**Thread EN 10226-1 R / R<sub>p</sub>:** 1/2" – 3/4" – 1" – 5/4" – 6/4" – 2"

**Copper male end:** Ø22x1 – Ø28x1

**Gas meter end:** G4 – G6

**Model B2000 until B2024**

Stainless steel pliable corrugated tube

**Model B2025 until B2049**

Fitting, PLT end / male thread

**Model B2050 until B2061**

Fitting, 2 x PLT end

**Model B2062 until B2085**

Tee, 3 x PLT end

**Model B2086 until B2089**

Tee, 2 x PLT end / female thread

**Model B2090 until B2095**

Fitting, PLT end / copper male end

**Model B2096 until B2099**

Fitting, PLT end / gas meter end

**Model B2100 until B2105**

Fitting, PLT end / flange

**Model B2106 until B2119**

Wallplate 90°, PLT end / female thread

**Model B2120 until B2141**

Fitting, PLT end / female thread

Kenny VANLANCKER  
Laboratory Manager.